

DECLARATION OF PERFORMANCE: QuelStop Fire Pillows

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Product Name	QuelStop Fire Pillows	
Product Code(s)	QFP1, QFP2, QFP3	
Revision Date	01/01/2026	
Revision Number	01	

Section 1: Unique identification code of the product-type

QuelStop Fire Pillows

Section 2: Type, batch, or serial number as required under Article 11(4)

N/A

Section 3: Intended use(s) of the construction product according to the applicable harmonised technical specification

Fire stopping and sealing product for penetration seals, see UL-EU Certificate UL-EU-01222-CPR

Cable penetrations	Insulated and non-insulated cables, cable trays, and cable ladders	The field of application has to comply with the content of the related to UL-EU Certificate UL-EU-01222-CPR
--------------------	--	---

Section 4: Name, registered trade name or registered trademark, and contact address as required under Article 11(5)

Company	Quelfire Limited Unit 4 Spitfire Road Wardle Nantwich Cheshire CW5 6HT
Tel	0161 928 7308
Email	technical@quelfire.co.uk

Section 5: Authorised representative

Company N/A

Email N/A

Section 6: System(s) of assessment and verification of constancy of performance of the construction product as set out in Annex V

N/A

Section 7: Harmonised standard

N/A

Section 8: In the case of the declaration of performance concerning product covered by a harmonised standard and/or ETA

UL International UK Ltd has performed surveillance of the place of manufacture and the factory production control implemented issued the UL-EU Certificate UL-EU-01222-CPR.

DECLARATION OF PERFORMANCE: QuelStop Fire Pillows

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Section 9: Declared performance	
Essential Characteristic	Declared Performance/Harmonised Technical Specification
Reaction to Fire	Class F in accordance with EN 13501-1, see UL-EU-01222-CPR
Resistance to Fire	Resistance to fire performance and field application in accordance with EN 13501-2, see UL-EU-01222-CPR page 5
Air Permeability	In accordance with EN 1026:2000, see UL-EU-01222-CPR page 4
Water Permeability	No performance assessed
Dangerous Substances	See UL-EU-01222-CPR
Mechanical Resistance and Stability	No performance assessed
Resistance to Impact/Movement	No performance assessed
Adhesion	No performance assessed
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1, see UL-EU-01222-CPR
Impact Sound Insulation	No performance assessed
Durability and Serviceability	Z ² in accordance with EAD 350454-00-1104, Clause 2.2.9, see UL-EU-01222-CPR

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer, identified in point 4.

Signed for and on behalf of the manufacturer	
	
Alec Purdie Technical Manager	Darryl Wells Director