

DECLARATION OF PERFORMANCE: QuelCast Cast In Fire Collar

According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Product Name	QuelCast Cast In Fire Collar	
Product Code(s)	QUELCST50, QUELCST110, QUELCST160	
Revision Date	01/01/2026	
Revision Number	04	

Section 1: Unique identification code of the product-type

QuelCast Cast In Fire Collar

Section 2: Type, batch, or serial number as required under Article 11(4)

See batch number displayed on the product label

Section 3: Intended use(s) of the construction product according to the applicable harmonised technical specification

Fire stopping and sealing product for penetration seals, see ETA 20/1203

Pipe penetrations | Plastic pipes | The field of application must comply with the content of the related ETA 20/1203

Section 4: Name, registered trade name or registered trademark, and contact address as required under Article 11(5)

Company	Quelfire Limited Unit 4 Spitfire Road Wardle Nantwich Cheshire CW5 6HT
Tel	0161 928 7308
Email	technical@quelfire.co.uk

Section 5: Authorised representative

Company	Certification Company B.V. Veluwezoom 42 1327 AH Almere, Netherlands
Email	admin@certification-company.com

Section 6: System(s) of assessment and verification of constancy of performance of the construction product as set out in Annex V

System 1

Section 7: Harmonised standard

N/A

Section 8: In the case of the declaration of performance concerning product covered by a harmonised standard and/or ETA

Warrington Certification Ltd issued ETA Number 20/1203 on the basis of the Guideline for European Technical Approval of Fire Stopping and Fire Sealing Products: EAD 350454-00-1104, Issue September 2017.

The company performed initial and continuous surveillance of the place of manufacture and the factory production control implemented, sampled the product, and witnessed initial type testing under system 1.

UL International UK Ltd has performed surveillance of the place of manufacture and the factory production control implemented issued the Certificate of Constancy of Performance 2821-CPR-0263.

DECLARATION OF PERFORMANCE: QuelCast Cast In Fire Collar


According to Annex III of Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Section 9: Declared performance

Essential Characteristic	Declared Performance/Harmonised Technical Specification
Reaction to Fire	Class F according to EN 13501-1, see ETA 20/1203
Resistance to Fire	Resistance-to-fire performance and field application in accordance with EN 13501-2, see ETA 20/1203
Dangerous Substances	See ETA 20/1203 – declaration – compliant
Durability and Serviceability	Type X intended for use in conditions exposed to weathering in accordance with EAD 350454-00-1104, EOTA Technical Report – TR024, see ETA 20/1203
Other	Not applicable/no performance determined

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer, identified in point 4.

Signed for and on behalf of the manufacturer

	
Alec Purdie Technical Manager	Darryl Wells Director