QFP-RW150-06

Insulated Metal pipe Penetrating a rigid wall (150mm or thicker)

Quelfire

This standard detail is intended for general information only and all details should be checked against all relevant supporting test evidence, certification and installation guidelines

In line with the company's policy of continual development, details are subject to change and/ or withdrawal therefore you must ensure this is the latest published detail and instructions.

Additional Instructions


Rigid walls to be a minimum of 150mm thickness and have a minimum density of \geq 650kg/m³.

Pillows should be installed lengthways and in such a way that all joints are staggered in each layer and all gaps are filled in a manner that ensures a tight compression fit.

They should be finally positioned so that they are **centrally positioned** within the fire compartment wall with equal projection on both sides of the supporting construction.

Services wrapped with 2 x layers of ≥100mm long foil faced ≥6mm ceramic fibre insulation where they exit the seal.

BS EN 1366-3:2021 Section 13.7: The distance between the aperture edges of penetration seals in a building element shall be as tested or minimum 100mm. The distance between the aperture edge of a penetration seal and any other penetration (e.g., door) in a building element shall be minimum 200mm.



Substrate minimum thickness:

First Service Support:

Maximum Aperture:

Drawing Scale:

Issue Number:

Date of Issue:

Detail Reference:

150mm

≤250mm

Not to Scale

January 2023

QFP-RW150-06

1100 x 1100mm

Service Type	Size of Services	Pipe Wall Thickness	Pipe Insulation	Additional Pipe Insulation	Classification
Copper/ Cast Iron & Steel Pipe*	Ø54mm	1.0 - 14.2mm	15mm thick Armaflex AF (C/S)	≥6mm foil faced ceramic fibre insulation. ≥100mm (L/I)	EI 120 C/U

^{*} All metal pipe materials are covered which have a thermal conductivity equal or lower than the metal pipe tested and provided the melting point is at least equal or greater.

Important Information:

- 1. The supporting construction must be installed in accordance with the manufacturer's guidelines and must be capable of achieving the required fire rating of the firestop.
- 2. All Services should be adequately supported either side of the firestop to ensure that no load is transferred onto the firestop seal.

Scope and Liability:

- 1. Any Information provided by or on behalf of Quelfire Limited is provided for general information only. It is not intended to amount to advice on which you should rely. You must obtain professional or specialist advice before taking, or refraining from, any recommendation or action.
- 2. The summary is not exhaustive and does not consider all issues relevant to the enquiry. It is limited to the information and time available to us. We have not verified any information made available to us by you or any other source, nor have we carried out a physical inspection of any property. We make no representations, warranties or guarantees, whether expressed or implied, that any information is accurate, complete or up to date.
- 3. We do not accept a duty of care to you or any other person in respect of the enquiry, nor do we accept any liability to you or any other person for any loss arising out of or in connection with the enquiry or any reply provided by us. Different limitations and exclusions of liability arising as a result of the supply of any products or services by us to you, and these will be set out in our terms and conditions of supply, a copy of which is available on request.
- 4. Full terms and conditions of sale are available at https://www.quelfire.co.uk/terms-conditions-of-sale/